

Energy Management Accessories Type Eos-Gate

CARLO GAVAZZI



- Embedded PC with data acquisition, data logging and protocol conversion capabilities
- Internet Gateway from Eos-Array and Eos-Array Lite to Fat Spaniel® Web Platform
- Two RS485 communication ports (Modbus)
- Two Ethernet ports

Product Description

The Eos-Gate is a device which allows to monitor a photovoltaic installation by means of a remote Web Portal. The Eos-Gate polls data (measurements and alarms) from a set of monitoring devices installed in the plant location and transmits those data to a remote web-server through internet using a shared communication pro-

ocol. Data-logging features are used to secure the communication so to not lose data. The Eos-Gate polls data from the Carlo Gavazzi's AC meter and from the Eos-Array/Eos-Array Lite string combiner DC monitoring system, so that it provides a complete AC and DC monitoring of a photovoltaic plant. The Eos-

How to order

Eos-Gate D XX X

Model _____
Power Supply _____
Option _____
Special features _____

Gate transmits data to the Fat Spaniel® Portal using a push-based technology which avoids firewall related issues. The Fat Spaniel®

Portal is a web portal platform which allows the user to manage its data remotely with an easy and powerful web based user interface.

Type Selection

Power Supply

D: from 12 to 48VDC

Option

XX: none

Special features

X: none

Hardware

Type

Operating System
 Processor
 Operation

Embedded PC
 Linux kernel 2.6
 ARM9 RISC 32-bit 192Mhz
 Fan-less

Memory

RAM
 Flash ROM
 Integrated SD

32MB
 16MB
 1 GB industrial grade, SLC type

Alert tools

Built-in RTC (real-time clock)
 Built-in buzzer

Communication Port

Ethernet
 RS485

2 ports for internet/LAN connection
 1 port for Eos-Array/Eos-Array Lite and Carlo Gavazzi's AC meters connection
 1 port for third party devices

Supply specification

DC supply

12 to 48 VDC

Power-on indication

System ready LED

Power consumption

340 mA @ 12V (4.5W)

AC/DC power supply adapter

Universal power adapter included

Input/Output specifications

LAN Ethernet Connector "Link" indication	2 auto sensing 10/100 Mbps ports RJ45 Magnetic Isolation Protection: 1.5kV built-in LED 10M/Link (x2), 100M/Link (x2)	Indicators Baudrate	LED TxD (x2), RxD (x2) selectable from 9600bps to 115200bps
		Management Eos-Gate	Web based software for configuration and testing. The software is based on the Eos-Gate internal web server and allows to configure and test the Eos-Gate through a TCP/IP connection.
Serial Interface RS485 ports Connector ESD protection	2 DB9 male 15kV for all signals		

General specifications

Operating Temperature	-10°C to +60°C 5% to 95% RH (non-condensing)	Standard compliance Safety	UL/cUL (UL60950-1, CSA C22.2 No 60950-1-03) EN60950-1
Storage Temperature	-20°C to 80°C		
EMC	CE (EN55022 Class A, EN61000-3-2 Class A, EN61000-3-3, EN55024) FCC (Part 15 Subpart B, CISPR 22 Class A)	Approvals	CE
		Housing Dimensions (LxWxH)	100 x 26 x 111 mm
		Weight	Approx. 280 g (packing included)
		Mounting	wallmount or DIN rail

Main Function

Supported field devices	Carlo Gavazzi AC meter (up to 1 meter): EM21, EM24, EM26, WM30, WM40, WM5. Carlo Gavazzi DC monitoring device (up to 10 Eos Array): Eos-Array/Eos-Array Lite	Alarms Eos-Array Lite Electrical measurements	Eos-Array modules and sensors relevant Eos-Array's status information
Supported Web Portals	Fat Spaniel® Insight Platform and Fat Spaniel® Solar Vision	Environmental measurements	instantaneous values for DC current, DC voltage, at string level and string-combiner level. instantaneous values for ambient temperature and solar irradiation according to the installed Eos-Array Lite modules and sensors relevant Eos-Array Lite's status information
Polling time interval	Sampling interval: 30 seconds; data are transmitted to the remote web platform every 10 minutes	Alarms	
Historical data storing	up to 30 days if internet connection is out of order	Managed data for AC meters, 1-phase system	V= AC Voltage, instantaneous variable A= AC Current, instantaneous variable W = AC active power, instantaneous variable kWh= AC energy produced, instantaneous variable kWh+= AC energy consumed, instantaneous variable
Managed data Eos-Array Electrical measurements	instantaneous values for DC current, DC voltage, DC power, DC energy, string Efficiency at string level and string-combiner level.		
Environmental measurements	instantaneous values for ambient temperature, solar irradiation, wind speed according to the installed		

Main Function (cont.)

Managed data for AC meters, 3-phase 4-wires system

V_{L1} = AC Voltage phase L1, instantaneous variable;
 V_{L2} = AC Voltage phase L2, instantaneous variable;
 V_{L3} = AC Voltage phase L3, instantaneous variable;
 V_{L1-2} = AC Voltage phase L1 to L2, instantaneous variable;
 V_{L2-3} = AC Voltage phase L2 to L3, instantaneous variable;
 V_{L3-1} = AC Voltage phase L3 to L1, instantaneous variable;
 I_{L1} = AC Current phase L1, instantaneous variable;
 I_{L2} = AC Current phase L2, instantaneous variable;
 I_{L3} = AC Current phase L3, instantaneous variable;
 W_{L1} = AC Current phase L1, instantaneous variable;
 W_{L2} = AC Current phase L2, instantaneous variable;
 W_{L3} = AC Current phase L3, instantaneous variable;
 W_{sys} = AC active power, system, instantaneous variable;
 $kWh-$ = AC energy produced, instantaneous variable
 $kWh+$ = AC energy consumed, instantaneous variable


Managed data for AC meters, 3-phase 3-wires system

V_{L1-2} = AC Voltage phase A to B, instantaneous variable;
 V_{L2-3} = AC Voltage phase B to C, instantaneous variable;
 V_{L3-1} = AC Voltage phase C to A, instantaneous variable;
 I_{L1} = AC Current phase A, instantaneous variable;
 I_{L2} = AC Current phase B, instantaneous variable;
 I_{L3} = AC Current phase C, instantaneous variable;
 W_{L1} = AC Current phase A, instantaneous variable;
 W_{L2} = AC Current phase B, instantaneous variable;
 W_{L3} = AC Current phase C, instantaneous variable;
 W_{sys} = AC active power, system, instantaneous variable;
 $kWh-$ = AC energy produced, instantaneous variable
 $kWh+$ = AC energy consumed, instantaneous variable

Eos-GateSoft programming parameters

Internal web server	Configuration software based on a web server integrated into the Eos-Gate; the web based interface allows to configure parameters and test the Eos-Gate functionalities	Web Portal parameters configuration	Configuration of the relevant Web Portal parameters (internet address, authentication codes)
Network Configuration	RS485 parameters configuration TCP/IP network parameters configuration	Added services	dyndns management, NTP (network time protocol) synchronization
Field devices configuration	Scanning mode available for Eos-Array/Eos-Array Lite and Carlo Gavazzi's AC meters		

Example of communication architecture



Dimension

