



PRODUCT DATA SHEET

Controlled Document - Engineering Drive

1530 Shields Drive
Waukegan, IL 60085
Toll-Free (800) 323-9355
Fax: (847) 689-1192

PART NUMBER: 42468
DESCRIPTION: 12/3 W/GND THW ROUND PUMP/TC DIRECT BURIAL CABLE
CONSTRUCTION: This cable consists of three bare copper insulated conductors and a ground cabled with an overall jacket.
APPROVALS: UL Standards 83 and 1277, Type THW Submersible Pump Cable or Power and Control Tray Cable
APPLICATION: Underwater Pumps, Underground Power and Control, and Similar Applications

Construction Parameters:

Conductor	12 AWG Bare Copper
Stranding	19/.0185"
Insulation Material	PVC
Insulation Thickness	0.047" Nom.
Insulated Conductor Diameter	0.183" Nom.
Ground Wire	12 AWG 19 Strand PVC Insulated
Number of Conductors plus Ground	4
Lay Length	6.50" Nom.
Separator	Microdust
Jacket Material	PVC
Jacket Thickness	0.062" Nom.
Overall Cable Diameter	0.567" Nom.
Approximate Cable Weight	190.4 Lbs/1M' Nom.

Electrical Properties:

Temperature Rating	-20°C to 75°C Dry and Wet
Operating Voltage	600 V RMS Max.
DC Resistance per Conductor @ 20°C	1.58 Ohms/1M' Nom.

Insulation Colors	Black Yellow Red Green
Jacket Color	Black

Legend (Surface Ink Print)	CCI E79496 12 AWG (3.31mm ²) 3/C W/GND (UL) 600V TYPE THW INS. SUBMERSIBLE PUMP CABLE OR TYPE TC 75C DRY & WET DIR BUR SUN RES
----------------------------	--

This product complies with European Directive 2002/95/EC (RoHS)

The customer will accept all factory lengths and +/- 10 percent of total order requested.

The information presented here is, to the best of our knowledge, is true and accurate. However, since conditions of use are beyond our control, all recommendations or suggestions are presented without guarantee or responsibility on our part. We disclaim all liability in connection with the use of information contained herein or otherwise.

This specification is proprietary intellectual property of Coleman Cable. Any information contained herein shall not be disclosed to any party without written consent of Coleman Cable.

Customer Name _____

Customer Approval _____

Specification Issue Date: June 6, 2007