



PRODUCT DATA SHEET

Controlled Document - Engineering Drive

1530 Shields Drive
Waukegan, IL 60085
Toll-Free (800) 323-9355
Fax: (847) 689-1192

PART NUMBER: 44313
DESCRIPTION: 2/3 FLAT PUMP CABLE
CONSTRUCTION: This cable consists of three bare copper insulated conductors laid parallel with an overall jacket.
APPROVALS: UL Standard 83 (Ins. Walls), Overall Cable UL Listed Misc. Wires Submersible Pump Cable
APPLICATION: Underwater pumps and similar applications.

Construction Parameters:

Conductor	2 AWG Bare Copper
Stranding	19x35/30
Insulation Material	TPE
Insulation Thickness	0.061" Nom.
Insulated Conductor Diameter	0.449" Nom.
Number of Conductors	3
Lay Length	Parallel
Jacket Material	TPE
Jacket Thickness	0.050" Nom.
Overall Cable Diameter	0.554" x 1.447" Nom.
Approximate Cable Weight	842.0 Lbs/1M' Nom.

Electrical Properties:

Temperature Rating	-50°C to 90°C Dry, 75°C Wet
Operating Voltage	600 V RMS Max.
DC Resistance per Conductor @ 20°C	0.158 Ohms/1M' Nom.

Insulation Colors	Black Yellow Red
Jacket Color	Black

Legend (Surface Ink Print) CCI E54868 2 AWG (UL) 600V PUMP CABLE 90C DRY 75C WET

The jacket is sequentially footprinted from 2 to the footage designated by the put-up code.

The information presented here is, to the best of our knowledge, true and accurate. Since conditions of use are beyond Coleman Cable's control all product data presented is for informational purposes only and does not create a binding obligation or liability on Coleman Cable or confer any rights on any customer. The sale of products(s) is conditioned upon acceptance of a purchase order subject to Coleman Cable's standard terms and conditions contained therein, including without limitation Coleman Cable's standard warranty. Coleman cable disclaims all liability in connection with the use of information contained herein or otherwise.

This specification is proprietary intellectual property of Coleman Cable. Any information contained herein shall not be disclosed to any party without written consent of Coleman Cable.

Specification Issue Date: October 20, 2005