



PRODUCT DATA SHEET

Controlled Document - Engineering Drive

1530 Shields Drive
Waukegan, IL 60085
Toll-Free (800) 323-9355
Fax: (847) 689-1192

PART NUMBER: 54502
DESCRIPTION: 12 AWG SOLID UF/TWU CABLE
CONSTRUCTION: This cable consists of one bare copper insulated conductor.
APPROVALS: UL Standard 493, CSA 22.2 No.75
APPLICATION: Underground Feeder Cable for Direct Burial Applications

Construction Parameters:

Conductor	12 AWG Bare Copper
Stranding	Solid
Insulation Material	PVC
Insulation Thickness	0.061" Nom.
Insulated Conductor Diameter	0.202" Nom.
Number of Conductors	1

Electrical & Electrical Properties:

Temperature Rating	-20°C to 60°C
Operating Voltage	600 V RMS Max.
DC Resistance per Conductor @ 20°C	1.59 Ohms/1M' Nom.

Insulation Colors	Various
-------------------	---------

Legend (Surface Ink Print)	BARON WIRE E61390 12 AWG (3.31mm ²) (UL) TYPE UF 600V -- C(UL) TWU 60C FT1 -- XX/XX/XX (MONTH/DAY/YEAR) HH:MM (HOUR/MINUTE)
----------------------------	---

This product complies with European Directive 2011/65/EU (RoHS-2)

On special orders, the customer will accept all factory lengths and +/- 10 percent of total order requested.

The jacket is sequentially footmarked.

The information presented here is, to the best of our knowledge, true and accurate. Since conditions of use are beyond Coleman Cable's control, all product data presented is for informational purposes only and does not create a binding obligation or liability on Coleman Cable or confer any rights on any customer. The sale of product(s) is conditioned upon acceptance of a purchase order subject to Coleman Cable's standard terms and conditions contained therein, including without limitation Coleman Cable's standard warranty. Coleman Cable disclaims all liability in connection with the use of information contained herein or otherwise.

This specification is proprietary intellectual property of Coleman Cable. Any information contained herein shall not be disclosed to any party without written consent of Coleman Cable.

Specification Issue Date: August 21, 2013