

VIKING PRODUCT MANUAL

COMMUNICATION & SECURITY SOLUTIONS

Control Relay Contacts Across a Local Area Network

The RC-4 Network Enabled Relay Controller provides networked control of four remote relays via a web interface. The same interface can be used to check the status of four contact closures at the remote location.

Relays can be toggled on or off, or user-programmed timed closures can be activated. Two levels of user access permit selected users to have full operational and programming rights while others have operational control but not programming capability.



Features

- Terminal strip connections for normally open, normally closed, and common for all four relays
- Relays can be toggled or timed closures of from 1 - 99 seconds can be activated
- Terminal strip connections for all four sensor inputs
- Ready-to-use webpage control interface
- Encrypted login
- Two levels of access based on login:
 - Administrator (full access)
 - Guest (programmable limits)
- Relay names and input names can be customized on webpage
- Firmware remotely updateable

www.vikingelectronics.com
Information: (715) 386-8861

Does your application require email or text notification of input status changes?

Contact Viking for information about SP510.

Applications

Remote Control of:

- Secure building entry
- Heating/cooling equipment
- Pumps and fans
- Security system
- Gates
- Lighting
- Emergency tones

Specifications

Power: 120VAC/12VDC 500ma UL listed adapter provided

Dimensions: 133mm x 89mm x 44mm (5.25" x 3.5" x 1.75")

Shipping Weight: 0.73 kg (1.6 lbs)

Environmental: 0 C to 32 C (32 F to 90 F) with 5% to 95% non-condensing humidity

Relay Contact Ratings: 5A @ 30VDC/250VAC

Connections: (1) 12 position screw terminal block, (1) 6 position elevated screw terminal block

LAN Interface: (1) RJ45 10Base-T

Minimum Requirements: Windows XP and newer, Mac OSX or newer, Android 2.2 or newer, iOS4 or newer (iPhone requires chrome), Java-script enabled internet browser

B. Setting Up the RC-4 on the Network

The **RC-4** is controlled by a webpage that is accessed using a web browser. To connect to the page, it is necessary to know either the IP address of the **RC-4**, which is the address that was assigned by the network server when the **RC-4** powered up, or to know the host name of the **RC-4**. Once you are able to connect to the **RC-4**, it can be operated using the dynamic IP address assigned by the server or it can be programmed to use a static IP address.

1. Unit Name (Host Name) (Windows only)

When the **RC-4** is accessed using a browser, it is acting as a host. Most networks allow the user to address the host using the host name, which is a sort of nickname that can be used instead of typing in the full four-byte IP address of the host. The default host name of the **RC-4** is "myviking". Type <http://myviking> into the address bar of the browser and hit enter or click on the arrow. If the Viking **RC-4** access page comes up, proceed to **4. Authentication**.

If entering the host name produces a "cannot display the webpage" message, the network server was unable to translate the host name into an IP address. From this point, there are two ways to proceed. Both require finding out what IP address the network server assigned to the **RC-4**.

2. Dynamic IP Address (Windows and Mac OSX)

When the **RC-4** is connected to a network server and powered up, it receives an IP address from the network server. This address can be determined by using the Microchip TCP/IP Discoverer, which reads and displays it. The utility can be downloaded from Viking's website:

<http://www.vikingelectronics.com/download/rc-4ethernet.php>

Under Quick Links at the middle right of the home page, find Software Downloads and click on it. You can read the information and then scroll down to the bottom of the page and click on "I Accept". Find "Microchip TCP/IP Discoverer" in the list of selections, click on it and proceed with the download.

The Android version of this app is freely available in the Google Market. Search for "Viking Electronics" and download "RC-4 Discoverer." Wi-fi is required, finds local units only.

Once the discoverer has been downloaded, double-click on the icon to activate it. In the display that comes up, look for the line that has the host name "myviking". Just to the left of this entry is the IP address that has been associated with the **RC-4**. Type this into the browser's address bar and click to bring up the **RC-4** webpage. Note that from this point on the page can be accessed by clicking on this address in the browser history instead of manually entering it every time, as long as browser history is not cleared. Another way of setting up the first connection is to just double-click on the line in the discoverer display where the **RC-4** is shown. While this also connects to the webpage, it does not store the page in browser history, so it should be stored in favorites for future fast access.

If you have tried the steps above and are still not connected, see the last section, **Troubleshooting**.

3. Static IP Address

To set the **RC-4** up for operation with a static IP address, first arrange with your network administrator for an address on the server to be configured as a static IP address. Once this is done, use the default host name "rc4host" or the dynamic IP address obtained on powerup to connect to the **RC-4** (see sections 1 and/or 2 above). Click on "Settings" at the bottom left of the main page, and at the bottom of the Settings page, click on "Network Configuration". Find the Enable DHCP checkbox near the bottom and uncheck it. The text boxes below are no longer greyed out. In the IP Address box, enter the static IP address you want to use. The Gateway, Subnet Mask, Primary and Secondary DNS server boxes can be left unchanged. After making this change, it will likely be necessary to clear the hostname cache in order to connect with the new IP address. This can be done by entering "nbtstat -R" in the Windows command prompt window.

4. Authentication

The **RC-4** is securely accessed using the Digest Authentication procedure. There are two levels of access, each requiring the entry of a user name and password. The Guest level allows operation of the relays but not programming of their default closure times or changes to username and password or network configuration. The Administrator level allows both relay operation and programming (see **Programming** sections **A** and **B**). The default usernames and passwords are listed below.

Guest username: guest

Guest password: password


Admin username: admin

Admin password: viking

There is one guest username and password available, and one admin username and password. It is recommended that these be changed to unique values for better security. If you forget your username and password, see **C. DIP Switch Programming**, Switch 3 to return to the original factory settings and reprogram the usernames and passwords. **Note:** *If secure login is not required, the **RC-4** can be programmed to skip authentication. See **Operation Without Authentication** on page 8.*

C. DIP Switch Programming

Switch	Position	Description
1	OFF	Logic Level 12V with a 6V trip point
1	ON	Logic Level 5V with a 2.5V trip point
2	OFF	Programming access is enabled
2	ON	Programming access is blocked
3	OFF	Normal operation
3	ON	Restore factory programming defaults
4	OFF	For future use (leave in OFF position)



Note: The default setting for all dipswitches is OFF.

Switch 1 – Logic Level

This dipswitch lets you set the logic level for the contact closure inputs. In the default OFF position, the logic level is 12V with a 6V trip point, which is best for long, relatively noisy runs. The higher trip point makes the input more immune to noise. Closing the switch sets a 5V logic level with a 2.5V trip point. This is the preferred level for a short run to another device with a similar logic level.

Switch 2 – Programming


Dipswitch 2 allows programming on the Set Defaults and Network Configuration pages. It works in conjunction with the user's authentication level. If the user is logged in as a Guest, no programming is possible. The programming pages can be accessed, and the programmable values are visible in their textboxes, but they are greyed out and can't be changed. It's when the user is logged in as an Administrator that Dipswitch 2 makes a difference. If Dipswitch 2 is OFF, programming is permitted. If Dipswitch 2 is ON, programming is blocked, even when the user is logged in as an Administrator. This hardware switch provides an additional level of security against hacking. To take advantage of this feature, turn Dipswitch 2 ON when programming is completed to lock the settings. If security is less of a concern, Dipswitch 2 could be left OFF and remote programming will always be permitted if the user is an Administrator.

Switch 3 – Restore Defaults


Dipswitch 3 allows a complete return to factory defaults, including all network addresses, username and password, and programmed time values. To return to defaults, the RC-4 must be powered down. With the unit powered down, turn on Dipswitch 3. Power up the RC-4. After four to eight seconds, the Status LED starts flashing. Turn Dipswitch 3 back off. After a second or two the status LED returns to steady on, and the return to defaults procedure is complete.

Operation

Connect to the webpage as described in **Installation** section **B. Setting Up the RC-4 on the Network** on page 3. The RC-4 access page appears.











Near the top of the page, locate and click on "Click here for access". The browser's authentication dialog appears.



For User Name, enter "admin", and for Password, enter "viking". The main page appears. Note that all four remote switches are shown Open and the relays are all Off.



Model: RC-4 - Unit Name: MYVIKING

Inputs	Relays	Timed Closures
Input 1: Open	 Relay 1: Off	2 
Input 2: Open	 Relay 2: Off	2 
Input 3: Open	 Relay 3: Off	2 
Input 4: Open	 Relay 4: Off	2 

[Settings](#)

[About](#)

The relays may be toggled On or Off, or they may be programmed to provide a timed closure of from 1 to 99 seconds. Relay 1 is red, which indicates that it is Off. Click on the image of the red circle next to "Relay 1". The circle changes from red to green, and relay 1 is turned on.



Model: RC-4 - Unit Name: MYVIKING

Inputs	Relays	Timed Closures
Input 1: Open	 Relay 1: On	<input type="text" value="2"/> <input type="button" value="Go"/>
Input 2: Open	 Relay 2: Off	<input type="text" value="2"/> <input type="button" value="Go"/>
Input 3: Open	 Relay 3: Off	<input type="text" value="2"/> <input type="button" value="Go"/>
Input 4: Open	 Relay 4: Off	<input type="text" value="2"/> <input type="button" value="Go"/>

[Settings](#)

[About](#)

To toggle Relay 1 back off, click on the green circle, it changes to red, and Relay 1 turns off.

To activate a timed closure, click on the "Go" button next to the relay. The closure is activated for the number of seconds shown in the box.

In the picture below, all four relays have had timed closures activated. Relays 1 and 2 had short closures and have already returned to the Off state. Relays 3 and 4 had longer times programmed and are still in the On position. When their times are up, they will return to the Off position.



Model: RC-4 - Unit Name: MYVIKING

Inputs	Relays	Timed Closures
Input 1: Open	 Relay 1: Off	<input type="text" value="1"/> <input type="button" value="Go"/>
Input 2: Open	 Relay 2: Off	<input type="text" value="10"/> <input type="button" value="Go"/>
Input 3: Open	 Relay 3: On	<input type="text" value="50"/> <input type="button" value="Go"/>
Input 4: Open	 Relay 4: On	<input type="text" value="99"/> <input type="button" value="Go"/>





[Settings](#)

[About](#)

The RC-4 also provides a status indication for the four inputs on the terminal block. In the pictures, inputs 1 and 3 are shown as Open and inputs 2 and 4 are shown as Closed. This indication is constantly refreshed so that the status indication is always current.



Model: RC-4 - Unit Name: MYVIKING

Inputs	Relays	Timed Closures
Input 1: Open	 Relay 1: Off	<input type="text" value="2"/> <input type="button" value="Go"/>
Input 2: Closed	 Relay 2: Off	<input type="text" value="2"/> <input type="button" value="Go"/>
Input 3: Open	 Relay 3: Off	<input type="text" value="2"/> <input type="button" value="Go"/>
Input 4: Closed	 Relay 4: Off	<input type="text" value="2"/> <input type="button" value="Go"/>

Settings
About

Programming

A. Settings Page

From the main page, click on "Settings". The settings page appears. **Note:** Only a user logged in as administrator can make changes on the Settings page. Guest users can not make changes and will get a "Programming pages are locked" message at the bottom of the Settings page.



Model: RC-4 - Unit Name: MYVIKING

Settings

This page allows setting of the input and relay names, default relay closure times, usernames and passwords, and guest access control.

Input Names	Input Status Phrasing								
<input type="text" value="1: Input 1"/> <input type="text" value="2: Input 2"/> <input type="text" value="3: Input 3"/> <input type="text" value="4: Input 4"/> <input type="button" value="Apply Input Names"/>	<table><tbody><tr><td>1 Open: <input type="text" value="Open"/></td><td>Closed: <input type="text" value="Closed"/></td></tr><tr><td>2 Open: <input type="text" value="Open"/></td><td>Closed: <input type="text" value="Closed"/></td></tr><tr><td>3 Open: <input type="text" value="Open"/></td><td>Closed: <input type="text" value="Closed"/></td></tr><tr><td>4 Open: <input type="text" value="Open"/></td><td>Closed: <input type="text" value="Closed"/></td></tr></tbody></table> <input type="button" value="Apply Input Status Text"/>	1 Open: <input type="text" value="Open"/>	Closed: <input type="text" value="Closed"/>	2 Open: <input type="text" value="Open"/>	Closed: <input type="text" value="Closed"/>	3 Open: <input type="text" value="Open"/>	Closed: <input type="text" value="Closed"/>	4 Open: <input type="text" value="Open"/>	Closed: <input type="text" value="Closed"/>
1 Open: <input type="text" value="Open"/>	Closed: <input type="text" value="Closed"/>								
2 Open: <input type="text" value="Open"/>	Closed: <input type="text" value="Closed"/>								
3 Open: <input type="text" value="Open"/>	Closed: <input type="text" value="Closed"/>								
4 Open: <input type="text" value="Open"/>	Closed: <input type="text" value="Closed"/>								
Relay Names	Closure Times								
<table><tbody><tr><td>Relay 1: <input type="text" value="Relay 1"/></td></tr><tr><td>Relay 2: <input type="text" value="Relay 2"/></td></tr><tr><td>Relay 3: <input type="text" value="Relay 3"/></td></tr><tr><td>Relay 4: <input type="text" value="Relay 4"/></td></tr></tbody></table> <input type="button" value="Apply Relay Names"/>	Relay 1: <input type="text" value="Relay 1"/>	Relay 2: <input type="text" value="Relay 2"/>	Relay 3: <input type="text" value="Relay 3"/>	Relay 4: <input type="text" value="Relay 4"/>	<table><tbody><tr><td>Relay 1: <input type="text" value="2"/> Seconds</td></tr><tr><td>Relay 2: <input type="text" value="2"/> Seconds</td></tr><tr><td>Relay 3: <input type="text" value="2"/> Seconds</td></tr><tr><td>Relay 4: <input type="text" value="2"/> Seconds</td></tr></tbody></table> <input type="button" value="Apply Times"/>	Relay 1: <input type="text" value="2"/> Seconds	Relay 2: <input type="text" value="2"/> Seconds	Relay 3: <input type="text" value="2"/> Seconds	Relay 4: <input type="text" value="2"/> Seconds
Relay 1: <input type="text" value="Relay 1"/>									
Relay 2: <input type="text" value="Relay 2"/>									
Relay 3: <input type="text" value="Relay 3"/>									
Relay 4: <input type="text" value="Relay 4"/>									
Relay 1: <input type="text" value="2"/> Seconds									
Relay 2: <input type="text" value="2"/> Seconds									
Relay 3: <input type="text" value="2"/> Seconds									
Relay 4: <input type="text" value="2"/> Seconds									

1. Input Names

The input names displayed on the main page can be customized by entering new names in the Input Names group textboxes. Up to 16 characters are permitted, including upper and lower case alphabet, numbers, spaces and the underscore character. When you are through entering the new names, click on "Apply Input Names" to save them.

2. Relay Names

The procedure for customizing relay names is the same as for input names, with 16 characters allowed and the same list of permitted characters. Clicking on "Apply Relay Names" saves the new names.

3. Input Status Phrasing

This refers to the way the states of the inputs are described on the main page and in emails. The default state descriptions are Open/Closed, but other possibilities might be Running/Stopped, Up/Down or In/Out. Up to 12 characters are allowed with the same list of characters as input names and relay names. To save the input status phrasing changes, click on "Apply Input Status Text".

4. Closure Times

The closure times for timed closures are shown in this group. The time shown in the box next to a relay on the main page is the time that relay remains activated when the "Go" button is clicked. Note that these times can be overridden by entering another value in the timed closures box on the main page and clicking "Go". The next time the main page is activated, however, the default time value will appear again in the box. The default closure time values are what is set here. To change one or more time values on the Settings page, enter the new values in the boxes and click "Apply Times". The **RC-4** accepts whole integer values from 1 – 99, corresponding to closure time in seconds.

Username and Passwords

Admin Username and Password

New Username:

New Password:

Confirm Password:

Guest Username and Password

New Username:

New Password:

Confirm Password:

Guest Access Control

View Inputs and Relays

Input 1: <input checked="" type="checkbox"/>	Relay 1: <input checked="" type="checkbox"/>
Input 2: <input checked="" type="checkbox"/>	Relay 2: <input checked="" type="checkbox"/>
Input 3: <input checked="" type="checkbox"/>	Relay 3: <input checked="" type="checkbox"/>
Input 4: <input checked="" type="checkbox"/>	Relay 4: <input checked="" type="checkbox"/>

Function Control

Toggle Relays:

Timed Activation:

Edit Activation Time:

Allow Firmware Update

[Return to Main Page](#)

[Network Configuration](#)

[Create Link](#)

[About](#)

5. Usernames and Passwords

To change the username and password, enter the new text and click on "Apply Admin Username and Password" or "Apply Guest Username and Password". Permitted characters are upper and lowercase alphabet (case sensitive), numbers and the underscore character. Up to 10 characters are allowed. When you click on the button, the **RC-4** stores the change and offers a link to the main page. If the administrator username and password were changed, the browser's username/password dialog comes up again to allow re-authentication with the new values.

Note: Operation Without Authentication

In the event that secure login is not required, the **RC-4** can be programmed to skip the authentication step and go directly from the "Click here for access" page to the main page. To do this, go to the **RC-4** Settings page and locate the Usernames and Passwords section near the bottom. The New Username, New Password and Confirm Password textboxes will be blank for both Admin and Guest. First, leaving all textboxes blank, click on "Apply Guest Username and Password". This warning appears:

Warning: Username and/or Password is blank, hit OK to accept or cancel to change.

Click on "OK". Click on the link to the main page that is offered at the top left of the resulting blank page, and return to the Settings page. Leaving the Admin Username and Password textboxes blank, click on "Apply Admin Username and Password". When the warning appears, click on "OK". Click on the link to the main page to return. It should be noted that this method of operation is not secure and should only be used on networks where unauthorized use would not be a problem.

Note: To revert back to secure login name and passwords, either program an administrative name and password first and guest username and password second, or use dip switch 3 to restore both user names and passwords to their default values (see **Restore Defaults** on page 3).

6. User Access Control

Near the bottom of the Settings page is a series of checkboxes to allow precise control of which functions are allowed when the user is logged in as a guest. These limitations apply only to the Guest login; users logged in as Administrator retain full privileges and functionality.

The Show Inputs and Relays group lets you decide which inputs or relays appear on the main page. If an input or relay is checked, it appears on the main page; if not, it does not appear on the main page for those logged in as guests, and consequently it is not accessible to them.

The Function Control group allows for more precise control of the relays. The ability to toggle relays, activate timed relay closures, or edit the activation time on the main page can be turned on or off.

The Allow Firmware Update box can be unchecked as an additional security precaution. This setting is universal in the sense that it applies to both Admin and Guest logins. If the box is unchecked, firmware updates are unconditionally blocked. However, the firmware update procedure allows an Admin user to override the block for the duration of the update.

B. Network Configuration Button

At the bottom of the Settings page, click on Network Configuration. The Network Configuration page appears.



Model: RC-4 - Unit Name: MYVIKING

Network Configuration

This page allows the configuration of the RC-4's network settings.

CAUTION: Incorrect settings may cause the board to lose network connectivity. Recovery options will be provided on the next page.

Enter the new settings for the board below:

MAC Address: 18:E8:0F:45:D9:6C

Host Name:

Port Number:

Enable DHCP

IP Address:

Gateway:

Subnet Mask:

Primary DNS:

Secondary DNS:

[Return to Main Page](#)

[Settings](#)

[About](#)

Copyright © 2012 Viking Electronics, Inc.

The following items are displayed:

MAC Address: This is for display only, since the MAC address cannot be changed.

Host Name (Unit Name): The current host name appears in this box. The default host name, MYVIKING, can be changed to provide a more user-specific name or to distinguish between multiple RC-4's installed on the same network. The host name can be 1 - 15 characters long, must begin with a letter, can not contain any spaces, is not case-sensitive and can include the underscore character.

Port Number: This should be left set to 80.

Enable DHCP: With the Enable DHCP box checked, all of the addresses below and the subnet mask are greyed out because they have already been fixed by the DHCP server. Unchecking the DHCP box disables DHCP and makes it possible to set the addresses manually in order to have a static IP address. These changes should only be made by a qualified network administrator.

IP Address

Gateway

Subnet Mask

Primary DNS Server

Secondary DNS Server

To save network configuration settings, click on "Save Settings". The Reboot page appears, and the RC-4 makes the changes, reboots, and displays the host name. Reconnection instructions are offered in the event the configuration changes result in a loss of connection.

Troubleshooting

Here are some suggestions if you are unable to connect with the **RC-4** webpage.

Check that the **RC-4** has power (Status LED should be lit).

Check that the network cable is OK.

Power up the **RC-4** and connect it to the network.

Run the Microchip TCPIP Discoverer.

Does the **RC-4** show up on the display?

NO Return the unit to defaults (Installation C. DIP switch programming,

Switch 3)

Try the Microchip TCPIP Discoverer again

Does the **RC-4** show up on the display?

NO Call Tech Support (see below).

YES

Find the line the **RC-4** is on and double-click on it.

Do you connect with the **RC-4** webpage?

NO Call Tech Support (see below).

YES

At this point, you can connect to the website by manually typing in the IP address shown in the Microchip TCPIP Discoverer window and connecting in the future by clicking on the address in the browser history, or by saving the website as a browser favorite. Do you want to do this?

YES Done

NO

The other way to access the **RC-4** page is to type in the host name in the address window. Try each of these items, and then try connecting using the **RC-4** host name.

Clear the browser cache

From the command prompt in Windows, enter "nbtstat -R" to clear the hostname cache

Edit the hosts file of your PC to include the RC-4 hostname

In Windows XP, Vista, and Windows 7, the path to the hosts file is

C:/Windows/System32/drivers/etc/hosts

Follow the directions in the file for adding a host, entering the IP address of the **RC-4** on a new blank line and "myvikings" on the same line, with a space between them.

If you have not done so already, try returning the unit to defaults (Installation C. DIP switch programming, Switch 3).

If none of these suggestions help, it will be necessary to call tech support.

TO CALL TECH SUPPORT: Call 715-386-8666 M-F 8:00 AM to 5:00 PM CST

Warranty

IF YOU HAVE A PROBLEM WITH A VIKING PRODUCT, CONTACT: VIKING TECHNICAL SUPPORT AT (715) 386-8666

Our Technical Support Department is available for assistance Monday through Friday 8am - 5pm central time. So that we can give you better service, before you call please:

1. Know the model number, the serial number and what software version you have (see serial label).
2. Have your Product Manual in front of you.
3. It is best if you are on site.

RETURNING PRODUCT FOR REPAIR

The following procedure is for equipment that needs repair:

1. Customer must contact Viking's Technical Support Department at 715-386-8666 to obtain a Return Authorization (RA) number. The customer MUST have a complete description of the problem, with all pertinent information regarding the defect, such as options set, conditions, symptoms, methods to duplicate problem, frequency of failure, etc.
2. Packing: Return equipment in original box or in proper packing so that damage will not occur while in transit. Static sensitive equipment such as a circuit board should be in an anti-static bag, sandwiched between foam and individually boxed. All equipment should be wrapped to avoid packing material lodging in or sticking to the equipment. Include ALL parts of the equipment. C.O.D. or freight collect shipments cannot be accepted. Ship cartons prepaid to: **Viking Electronics, 1531 Industrial Street, Hudson, WI 54016**
3. Return shipping address: Be sure to include your return shipping address inside the box. We cannot ship to a PO Box.
4. RA number on carton: In large printing, write the R.A. number on the outside of each carton being returned.

RETURNING PRODUCT FOR EXCHANGE

The following procedure is for equipment that has failed out-of-box (within 10 days of purchase):

1. Customer must contact Viking's Technical Support at 715-386-8666 to determine possible causes for the problem. The customer MUST be able to step through recommended tests for diagnosis.
2. If the Technical Support Product Specialist determines that the equipment is defective based on the customer's input and troubleshooting, a Return Authorization (R.A.) number will be issued. This number is valid for fourteen (14) calendar days from the date of issue.
3. After obtaining the R.A. number, return the approved equipment to your distributor, referencing the R.A. number. Your distributor will then replace the Viking product using the same R.A. number.
4. **The distributor will NOT exchange this product without first obtaining the R.A. number from you. If you haven't followed the steps listed in 1, 2 and 3, be aware that you will have to pay a restocking charge.**

TWO YEAR LIMITED WARRANTY

Viking warrants its products to be free from defects in the workmanship or materials, under normal use and service, for a period of two years from the date of purchase from any authorized Viking distributor. If at any time during the warranty period, the product is deemed defective or malfunctions, return the product to Viking Electronics, Inc., 1531 Industrial Street, Hudson, WI., 54016. Customer must contact Viking's Technical Support Department at 715-386-8666 to obtain a Return Authorization (R.A.) number.

This warranty does not cover any damage to the product due to lightning, over voltage, under voltage, accident, misuse, abuse, negligence or any damage caused by use of the product by the purchaser or others. This warranty does not cover non-EWP products that have been exposed to wet or corrosive environments. This warranty does not cover stainless steel surfaces that have not been properly maintained.

NO OTHER WARRANTIES. VIKING MAKES NO WARRANTIES RELATING TO ITS PRODUCTS OTHER THAN AS DESCRIBED ABOVE AND DISCLAIMS ANY EXPRESS OR IMPLIED WARRANTIES OR MERCHANTABILITY OR FITNESS FOR ANY PARTICULAR PURPOSE.

EXCLUSION OF CONSEQUENTIAL DAMAGES. VIKING SHALL NOT, UNDER ANY CIRCUMSTANCES, BE LIABLE TO PURCHASER, OR ANY OTHER PARTY, FOR CONSEQUENTIAL, INCIDENTAL, SPECIAL OR EXEMPLARY DAMAGES ARISING OUT OF OR RELATED TO THE SALE OR USE OF THE PRODUCT SOLD HEREUNDER.

EXCLUSIVE REMEDY AND LIMITATION OF LIABILITY. WHETHER IN AN ACTION BASED ON CONTRACT, TORT (INCLUDING NEGLIGENCE OR STRICT LIABILITY) OR ANY OTHER LEGAL THEORY, ANY LIABILITY OF VIKING SHALL BE LIMITED TO REPAIR OR REPLACEMENT OF THE PRODUCT, OR AT VIKING'S OPTION, REFUND OF THE PURCHASE PRICE AS THE EXCLUSIVE REMEDY AND ANY LIABILITY OF VIKING SHALL BE SO LIMITED.

IT IS EXPRESSLY UNDERSTOOD AND AGREED THAT EACH AND EVERY PROVISION OF THIS AGREEMENT WHICH PROVIDES FOR DISCLAIMER OF WARRANTIES, EXCLUSION OF CONSEQUENTIAL DAMAGES, AND EXCLUSIVE REMEDY AND LIMITATION OF LIABILITY, ARE SEVERABLE FROM ANY OTHER PROVISION AND EACH PROVISION IS A SEPARABLE AND INDEPENDENT ELEMENT OF RISK ALLOCATION AND IS INTENDED TO BE ENFORCED AS SUCH.

PART 15 LIMITATIONS

This equipment has been tested and found to comply with the limits for a Class A digital device, pursuant to Part 15 of the FCC Rules. These limits are designed to provide reasonable protection against harmful interference when the equipment is operated in a commercial environment. This equipment generates, uses, and can radiate radio frequency energy and, if not installed and used in accordance with the instruction manual, may cause harmful interference to radio communications. Operation of this equipment in a residential area is likely to cause harmful interference in which case the user will be required to correct the interference at his own expense.

Product Support: (715) 386-8666

Due to the dynamic nature of the product design, the information contained in this document is subject to change without notice. Viking Electronics, and its affiliates and/or subsidiaries assume no responsibility for errors and omissions contained in this information. Revisions of this document or new editions of it may be issued to incorporate such changes.